

FIU

Applied Research
Center



DOE-FIU Cooperative Agreement Annual Research Review – FIU Year 1

Project 3 Task 2 (D&D)

Philip Moore (DOE Fellow)

*Worlds
Ahead*


Advancing the research and academic mission of Florida International University

Overall Needs:

- fixative technology to immobilize and/or isolate residual contamination within a 3D void space. These fixatives need to remain functional under a number of stressors (thermal, impact, and environmental). This helps mitigate risk of worker / environmental exposure during D&D activity.


Objectives:

- Identify COTS Technologies
- Down-select technology after lab scale testing
- Cold demo planning in progress
- Onsite demo in radioactive environment



FIU Year 1 Highlights:


- Plug strength
 - Effects of stressors is determined by the change in plug strength (the force required to remove the fixative from a steel pipe).
 - Evaluated on MTS tensile tester with a plunger and bucket device.



Stressors for Pipe Sample Testing

FIU Year 1 Highlights:

- Water Immersion
 - Samples were submerged in 3 feet of water for 8, 12 and 24 hours.
- Free Drop
 - Drop heights – 4 ft., 8 ft. and 12 ft. onto a stainless-steel plate.
- Direct flame test
 - A propane torch that reaches temperatures greater than 1475 °F was placed at each end of the sample.




a) 4 ft. setup; b) 8 ft. setup; c)
12 ft. setup



2" Diameter 2" long Hilti Pipe Sample Testing

FIU Year 1 Highlights:



Water and impact stressors had **MINIMAL** impact to plug strength.


Direct flame test results may be misleading due to the small volume used.



3" Diameter 14" long Hilti Pipe Sample Testing

FIU Year 1 Highlights:

- Testing was transitioned to 3" dia. 14" long pipe samples to test a full cartridge of Hilti.
 - This was also to verify formula to calculate adhesive strength of Hilti based on surface area of a steel substate.
- End Centered Flame
 - Propane torches were placed at each end of the pipe.




3" Diameter 14" long Hilti Pipe Sample Testing

FIU Year 1 Highlights:

Center Focused Thermal Stressor



2 propane torches were placed at the center of each sample




All samples exhibited significant off gassing



One sample pushed out ~4in. of foam, likely due to a buildup of pressure at the center.

3" Diameter 14" long Hilti Pipe Sample Testing

FIU Year 1 Highlights:




Most stressors had **MINIMAL** impact to plug strength.

Except for direct flame testing at the sides/center of the pipe.



FIU Year 1 Highlights:

- Fellow Philip Moore continued work with polyurethane foams during his internship at SRNL.
 - Foams were cured in an environmental chamber to test response to temperature and humidity outside of manufacturers' ideal conditions.
 - Tested for, "set to touch", "dust free", and "dry to touch" times according to ASTM 1640.
- SRNL is continuing environmental chamber testing on this set of foams.



Future work

- Continued testing of 3" diameter 14" long pipe samples
- Cold demo test plan
 - FIU will simulate an application environment provided by SRNL. The foam fixative will be deployed and observed regularly to determine efficacy.
- Onsite demo in radioactive conditions
 - Vital to understanding fixatives response to actual site conditions.



Acknowledgments

- **DOE-FIU Science and Technology Workforce Development Program**
- **Sponsored by the U.S. Department of Energy, Office of Environmental Management, under Cooperative Agreement #DE-EM00005213.**





Thank You. Questions?